


FRONT VIEW

NEUTRAL

SECTION A-A

SIDE VIEW

(ILLUSTRATES NEUTRAL ONLY)



RECOMMENDED FRONT CUT-OUT

**OPERATOR DETAILS**

FOR OPERATOR DETAILS AND ALTERNATE FRONT CUT-OUTS, REFER TO THE FOLLOWING DRAWINGS:  
 O-1023A MANUAL OPERATOR  
 O-1090A SHUNT TRIP OPERATOR

**KEY INTERLOCK**

KEY INTERLOCK SPECIFICATIONS FOR SWITCHES EQUIPPED WITH KEY INTERLOCK PROVISIONS ARE:  
 .375 BOLT PROJECTION WHEN WITHDRAWN  
 - KIRK TYPE B  
 - SUPERIOR TYPE B6003

AMP	CATALOG NUMBER				NET WT. (3-P, 3-W)	A	B	C	D			E	F	G
	2-P, 2-W	2-P, 3-W	3-P, 3-W	3-P, 4-W					GND.	INS.				
4000	SL2613	SL3613-N	SL3613	SL4613-N	285 LBS	4	1.125	15.25	16	8	80 SQ. IN.	1	6	
5000	SL2614		SL3614		325 LBS	5	1.625	17.25	16	8	120 SQ. IN.			
6000	SL2615		SL3615		380 LBS	5	1.625	17.25	16	8	120 SQ. IN.			

NOTE: FOR SWITCHES EQUIPPED WITH OPTIONAL SHUNT TRIP, ADD SUFFIX -ST TO CATALOG NUMBER

**VENTILATION**

WHEN THE SWITCH IS TOTALLY ENCLOSED, VENTILATING LOUVRES MUST BE PROVIDED YIELDING A MINIMUM OPEN AREA OF "E" SQUARE INCHES NEAR THE TOP OF THE ENCLOSURE, AND "E" SQUARE INCHES NEAR THE BOTTOM OF THE ENCLOSURE.

**SERIES SL SWITCHES, 4000-6000 AMP**  
**2P/2W, 2P/3W, 3P/3W, 3P/4W 600 VAC**

SCALE:	APPROVED BY:	DRAWN BY WCE
DATE: 10-10-91		REVISED 1

**boltswitch, inc.**  
CRYSTAL LAKE, ILLINOIS 60014

DRAWING NUMBER  
**O-1025**